

The Bays WTP Sampling and Discharge Summary- April

Discharge Date	Site/WTP	pH	Turbidity/TSS	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units	NTU	Y/N
		6.5-8.5	18	Not visible
1/04/2023	C-WTP	6.74	6.3	N
2/04/2023	C-WTP	7.07	10.4	N
3/04/2023	C-WTP	7.05	12.5	N
4/04/2023	C-WTP	7.73	5	N
5/04/2023	C-WTP	7.22	1.4	N
6/04/2023	C-WTP	6.97	1.4	N
7/04/2023	C-WTP	7.03	1.4	N
8/04/2023	C-WTP	7.42	3.9	N
9/04/2023	C-WTP	6.97	5.8	N
10/04/2023	C-WTP	6.88	6.4	N
11/04/2023	C-WTP	7.48	5	N
12/04/2023	C-WTP	7.26	12	N
13/04/2023	C-WTP	7.31	5.5	N
14/04/2023	C-WTP	7.31	1.4	N
15/04/2023	C-WTP	7.36	1.4	N
16/04/2023	C-WTP	7.32	1.4	N
17/04/2023	C-WTP	7.06	1.4	N
18/04/2023	C-WTP	7.22	12	N
19/04/2023	C-WTP	7.12	1.9	N
20/04/2023	C-WTP	7.43	8	N
21/04/2023	C-WTP	7.5	5.5	N
22/04/2023	C-WTP	7.58	6	N
23/04/2023	C-WTP	7.55	6	N
24/04/2023	C-WTP	7.45	1.4	N
25/04/2023	C-WTP	7.59	4.5	N
26/04/2023	C-WTP	7.59	9.9	N
27/04/2023	C-WTP	7.47	1.4	N
28/04/2023	C-WTP	7.44	1.4	N
29/04/2023	C-WTP	7.45	1.4	N
30/04/2023	C-WTP	7.74	6	N

Sydney Olympic Park- WTP Sampling and Discharge Summary- April

Sample Date	Site / WTP	pH	Turbidity	Oil and Grease
		Lab	TSS (Lab)	Visual
		pH units	mg/L	Y/N
		6.5-8.5	15	N
17/04/2023	SOP-WTP	4	5	N
20/04/2023	SOP-WTP	7.5	5	N
26/04/2023	SOP-WTP	7.5	5	N

Burwood- WTP Sampling and Discharge Summary- April

Sample Date	Site / WTP	pH	Turbidity	Oil and Grease
		Lab	TSS (Lab)	Visual
		pH units	mg/L	Y/N
		6.5-8.5	15	N
26/04/2023	BWD-WTP	7.6	5	N

Five Dock- WTP Sampling and Discharge Summary- April

Sample Date	Site / WTP	pH	Turbidity	Oil and Grease
		Lab	TSS (Lab)	Visual
		pH units	mg/L	Y/N
		6.5-8.5	15	N
14/04/2023	FDK-WTP	7.9	12	N
17/04/2023	FDK-WTP	8.1	5	N
18/04/2023	FDK-WTP	7.5	5	N
26/04/2023	FDK-WTP	7.3	5	N

Pre-cast yard- Sediment basin Discharge Summary- April

Sample Date	Site / WTP	pH	Turbidity/TSS	Oil and Grease
		Probe	Probe	Visual
		pH units	NTU	Y/N
		6.5-8.5	<50mg/l	N
26/04/2023	PCY	7.91	21.7	N