The Bays T-WTP Sampling and Discharge Summary- Feb

		pH	Turbidity	Oil and Grease
		Lab	TSS (Lab)	Visual
		pH units	mg/L	Y/N
		6.5-8.5	50	
Discharge Date	Site / WTP	6.5-8.5	50	
2/02/2023	TBY / T-WTP	7.8	48	N

The Bays- WTP Sampling and Discharge Summary-Feb

Discharge Date	Site/WTP	pH		Turbidity/TSS		Oil and Grease
		Lab	Probe	TSS (Lab)	Probe (correlation)	Visual
		pH units	pH units	mg/L	NTU	Y/N
		6.5-8.5	6.5-8.5	50	18	Not visible
7/02/2023	C-WTP	8.2		5		N
8/02/2023	C-WTP	-	7.74		1.6	N
9/02/2023	C-WTP	-	7.17		1.7	N
10/02/2023	C-WTP	-	6.66		1.6	N
14/02/2023	C-WTP	-	6.63		2	N
15/02/2023	C-WTP	-	6.62		4.5	N
15/02/2023	C-WTP	7.7		5		N
16/02/2023	C-WTP	-	7.43		1.5	N
17/02/2023	C-WTP	-	6.85		1.5	N
18/02/2023	C-WTP	-	6.71		1.5	N
19/02/2023	C-WTP	-	7.07		1.7	N
20/02/2023	C-WTP	7.5		5		N
20/02/2023	C-WTP	-	7.03		2.5	N
21/02/2023	C-WTP	-	6.71		1.5	N
22/02/2023	C-WTP	-	7.04		2.3	N
23/02/2023	C-WTP	-	7.03		2.3	N
24/02/2023	C-WTP	-	6.62		5.4	N
25/02/2023	C-WTP	-	6.61		4.9	N
26/02/2023	C-WTP	-	7.01		4.2	N
27/02/2023	C-WTP	-	6.73		6.6	N
28/02/2023	C-WTP	-	6.76		3.5	N
28/02/2023	C-WTP	7.8		5		N

Pre-cast yard Sampling and Discharge Summary- Feb

Discharge Date	Site	pH	Turbidity/TSS
		Probe	Probe
		pH units	NTU
2/02/2023	PCY	7.5	16.7

Burwood Sampling and Discharge Summary- Feb

Discharge Date	Site	pH	Turbidity/TSS
		Lab	TSS (Lab)
		pH units	mg/l
22/02/2023	BWD	7.8	<5