The Bays- Sampling and Discharge Summary-May

Discharge Date	Site/WTP	pH	Turbidity/TSS	Oil and Grease
		Lab	Lab	Visual
		pH units	NTU	Y/N
		6.5-8.5	15	Not visible
1/05/2023	TBY-C-WTP	7.4	20	N
17/05/2023	TBY-C-WTP	7.5	6	N

Sydney Olympic Park- WTP Sampling and Discharge Summary- May

Sample Date	Site / WTP	pH	Turbidity	Oil and Grease
		Lab	TSS (Lab)	Visual
		pH units	mg/L	Y/N
		6.5-8.5	15	N
1/05/2023	SOP-WTP	7.7	5	N
17/05/2023	SOP-WTP	7.5	5	N

Burwood- WTP Sampling and Discharge Summary- May

Sample Date	Site / WTP	pH	Turbidity	Oil and Grease
		Lab	TSS (Lab)	Visual
		pH units	mg/L	Y/N
		6.5-8.5	15	N
5/05/2023	BWD-WTP	7.7	5	N

Five Dock- WTP Sampling and Discharge Summary- May

Sample Date	Site / WTP	pH	Turbidity	Oil and Grease
		Lab	TSS (Lab)	Visual
		pH units	mg/L	Y/N
		6.5-8.5	15	N
5/05/2023	FDK-WTP	8.2	5	N
11/05/2023	FDK-WTP	7.5	5	N

Pre-cast yard- Sediment basin Discharge Summary- May

Sample Date	Site / WTP	pH	Turbidity/TSS	Oil and Grease
		Probe	Probe	Visual
		pH units	NTU	Y/N
		6.5-8.5	<50mg/l	N
3/05/2023	PCY	8.1	26.4	N
19/05/2023	PCY	7.62	20.7	N