

The Bays- WTP Discharge Summary - March 2025

Discharge Date	Site/WTP	pH units	NTU	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units	NTU	Y/N
		6.5-8.5	18	Not visible
1/03/2025	C-WTP	7.4	1.9	N
2/03/2025	C-WTP	7.5	2.3	N
3/03/2025	C-WTP	7.4	2.3	N
4/03/2025	C-WTP	7.5	2.4	N
5/03/2025	C-WTP	7.2	1.8	N
6/03/2025	C-WTP	7.3	1.8	N
7/03/2025	C-WTP	7.2	2	N
8/03/2025	C-WTP	7	1.7	N
9/03/2025	C-WTP	7	1.6	N
10/03/2025	C-WTP	6.9	1.7	N
11/03/2025	C-WTP	6.8	1.9	N
12/03/2025	C-WTP	6.8	1.5	N
13/03/2025	C-WTP	6.6	1.4	N
14/03/2025	C-WTP	6.6	1.6	N
15/03/2025	C-WTP	6.8	1.5	N
16/03/2025	C-WTP	6.8	1.4	N
17/03/2025	C-WTP	6.7	2.1	N
18/03/2025	C-WTP	6.9	1.5	N
19/03/2025	C-WTP	6.8	1.7	N
20/03/2025	C-WTP	6.9	1.8	N
21/03/2025	C-WTP	6.7	1.7	N
22/03/2025	C-WTP	6.8	3.1	N
23/03/2025	C-WTP	6.8	16.3	N
24/03/2025	C-WTP	6.9	1	N
25/03/2025	C-WTP	6.7	1.1	N
26/03/2025	C-WTP	6.6	1.3	N
27/03/2025	C-WTP	6.7	1.4	N
28/03/2025	C-WTP	7.1	1.4	N
29/03/2025	C-WTP	7	1.2	N
30/03/2025	C-WTP	7	1	N
31/03/2025	C-WTP	7.1	1.1	N

Burwood- WTP Discharge Summary- March 2025

Discharge Date	Site/WTP	pH units	NTU	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units	NTU	Y/N
		6.5-8.5	23	Not visible
1/03/2025	BWD-WTP	7.1	1	N
2/03/2025	BWD-WTP	7	1	N
3/03/2025	BWD-WTP	7.9	1.9	N
4/03/2025	BWD-WTP	7	1.1	N
5/03/2025	BWD-WTP	7	1.4	N
6/03/2025	BWD-WTP	7.1	1.2	N
7/03/2025	BWD-WTP	7.2	1.4	N
8/03/2025	BWD-WTP	7.2	1.4	N
10/03/2025	BWD-WTP	7.1	1.5	N
11/03/2025	BWD-WTP	7.1	1.5	N
12/03/2025	BWD-WTP	7	1.2	N
13/03/2025	BWD-WTP	7.1	1.1	N
14/03/2025	BWD-WTP	7	1	N
15/03/2025	BWD-WTP	7	1.1	N
17/03/2025	BWD-WTP	7	1.4	N
18/03/2025	BWD-WTP	6.7	1	N
20/03/2025	BWD-WTP	7.1	1	N
21/03/2025	BWD-WTP	7	1	N
24/03/2025	BWD-WTP	7.1	1	N
25/03/2025	BWD-WTP	7.2	1	N
31/03/2025	BWD-WTP	7.3	1.5	N