

The Bays- WTP Discharge Summary - March 2026

Discharge Date	Site/WTP	pH units	NTU	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units	NTU	Y/N
		6.5-8.5	18	Not visible
1/03/2026	TBY-WTP	7.1	1.3	N
2/03/2026	TBY-WTP	7.1	1.3	N
3/03/2026	TBY-WTP	7.1	1.3	N
4/03/2026	TBY-WTP	7.1	1.3	N
5/03/2026	TBY-WTP	7.1	1.3	N
6/03/2026	TBY-WTP	7.1	1.3	N
7/03/2026	TBY-WTP	7.1	1.3	N
8/03/2026	TBY-WTP	7.1	1.3	N
9/03/2026	TBY-WTP	7.1	1.3	N
10/03/2026	TBY-WTP	7.0	1.3	N
11/03/2026	TBY-WTP	7.0	1.3	N
12/03/2026	TBY-WTP	7.1	1.3	N
13/03/2026	TBY-WTP	7.1	1.2	N
14/03/2026	TBY-WTP	7.1	1.2	N
15/03/2026	TBY-WTP	7.1	1.2	N
16/03/2026	TBY-WTP	7.1	1.1	N
17/03/2026	TBY-WTP	7.1	1.1	N
18/03/2026	TBY-WTP	7.1	1.2	N
19/03/2026	TBY-WTP	7.1	1.1	N
20/03/2026	TBY-WTP	7.1	1.2	N
21/03/2026	TBY-WTP	7.1	1.2	N
22/03/2026	TBY-WTP	7.1	1.1	N
23/03/2026	TBY-WTP	7.1	1.1	N
24/03/2026	TBY-WTP	7.1	1.1	N
25/03/2026	TBY-WTP	7.0	1.2	N
26/03/2026	TBY-WTP	7.1	1.1	N
27/03/2026	TBY-WTP	7.1	1.2	N
28/03/2026	TBY-WTP	7.2	1.9	N
29/03/2026	TBY-WTP	No discharge	No discharge	N
30/03/2026	TBY-WTP	7.1	1.1	N
31/03/2026	TBY WTP no longer until AFJV control. EPL 21610 surrendered.			

Burwood North- WTP Discharge Summary- February 2026

Discharge Date	Site/WTP	pH units	NTU	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units	NTU	Y/N
		6.5-8.5	18	Not visible
18/03/2026	BWT-WTP	6.8	1.5	N
19/03/2026	BWT-WTP	6.9	1.6	N
24/03/2026	BWT-WTP	7.0	0.6	N
25/03/2026	BWT-WTP	6.9	0.3	N
26/03/2026	BWT-WTP	7.0	0.2	N
27/03/2026	BWT-WTP	7.1	1.3	N
28/03/2026	BWT-WTP	7.5	0.7	N
29/03/2026	BWT-WTP	No discharge	No discharge	N
30/03/2026	BWT-WTP	7.3	0.2	N
31/03/2026	BWT WTP no longer until AFJV control. EPL 21610 surrendered.			