

The Bays- WTP Discharge Summary - June 2025

Discharge Date	Site/WTP	pH units	NTU	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units	NTU	Y/N
		6.5-8.5	18	Not visible
1/06/2025	TBY-WTP	7.03	1.1	N
2/06/2025	TBY-WTP	7.08	1.3	N
3/06/2025	TBY-WTP	7.19	1.4	N
4/06/2025	TBY-WTP	7.01	1.3	N
5/06/2025	TBY-WTP	7.05	1.2	N
6/06/2025	TBY-WTP	7.04	1.0	N
7/06/2025	TBY-WTP	7.02	0.9	N
8/06/2025	TBY-WTP	7.05	1.1	N
9/06/2025	TBY-WTP	7.08	1.4	N
10/06/2025	TBY-WTP	7.13	1.4	N
11/06/2025	TBY-WTP	7.08	0.9	N
12/06/2025	TBY-WTP	7.06	1.1	N
13/06/2025	TBY-WTP	7.03	1.1	N
14/06/2025	TBY-WTP	7.04	1.1	N
15/06/2025	TBY-WTP	7.06	1.1	N
16/06/2025	TBY-WTP	7.05	1.1	N
17/06/2025	TBY-WTP	7.03	1.4	N
18/06/2025	TBY-WTP	7.06	1.2	N
19/06/2025	TBY-WTP	7.02	1.2	N
20/06/2025	TBY-WTP	7.04	1.2	N
21/06/2025	TBY-WTP	7.03	1.1	N
22/06/2025	TBY-WTP	7.05	1.2	N
23/06/2025	TBY-WTP	7.03	1.2	N
24/06/2025	TBY-WTP	7.04	1.1	N
25/06/2025	TBY-WTP	7.02	1.0	N
26/06/2025	TBY-WTP	7.06	1.1	N
27/06/2025	TBY-WTP	7.05	1.1	N
28/06/2025	TBY-WTP	7.08	1.0	N
29/06/2025	TBY-WTP	7.08	1.1	N
30/06/2025	TBY-WTP	7.07	1.1	N

Burwood North- WTP Discharge Summary- June 2025

No discharge during June 2025