

The Bays- WTP Discharge Summary - July 2025

Discharge Date	Site/WTP	pH units	NTU	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units	NTU	Y/N
		6.5-8.5	18	Not visible
1/07/2025	TBY-WTP	7.1	1.2	N
2/07/2025	TBY-WTP	7.1	1.4	N
3/07/2025	TBY-WTP	7.1	1.0	N
4/07/2025	TBY-WTP	7.0	1.2	N
5/07/2025	TBY-WTP	7.1	0.9	N
6/07/2025	TBY-WTP	7.1	0.7	N
7/07/2025	TBY-WTP	7.1	1.0	N
8/07/2025	TBY-WTP	7.1	1.0	N
9/07/2025	TBY-WTP	7.1	0.6	N
10/07/2025	TBY-WTP	7.1	1.1	N
11/07/2025	TBY-WTP	7.1	0.9	N
12/07/2025	TBY-WTP	7.1	1.6	N
13/07/2025	TBY-WTP	7.1	1.8	N
14/07/2025	TBY-WTP	7.1	1.3	N
15/07/2025	TBY-WTP	7.1	1.1	N
16/07/2025	TBY-WTP	7.1	1.3	N
17/07/2025	TBY-WTP	7.1	1.2	N
18/07/2025	TBY-WTP	7.1	1.6	N
19/07/2025	TBY-WTP	7.1	1.1	N
20/07/2025	TBY-WTP	7.1	1.6	N
21/07/2025	TBY-WTP	7.1	1.4	N
22/07/2025	TBY-WTP	7.1	1.2	N
23/07/2025	TBY-WTP	7.1	1.0	N
24/07/2025	TBY-WTP	7.1	1.0	N
25/07/2025	TBY-WTP	7.1	1.1	N
26/07/2025	TBY-WTP	7.1	1.4	N
27/07/2025	TBY-WTP	7.1	1.8	N
28/07/2025	TBY-WTP	7.1	1.4	N
29/07/2025	TBY-WTP	7.1	1.2	N
30/07/2025	TBY-WTP	7.1	1.4	N
31/07/2025	TBY-WTP	7.1	1.0	N

Burwood North- WTP Discharge Summary- July 2025

No discharge during July 2025