

The Bays- WTP Discharge Summary - September 2025

Discharge Date	Site/WTP	pH units	NTU	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units	NTU	Y/N
		6.5-8.5	18	Not visible
1/09/2025	TBY-WTP	7.1	1.3	N
2/09/2025	TBY-WTP	7.1	1.3	N
3/09/2025	TBY-WTP	7.1	1.3	N
4/09/2025	TBY-WTP	7.1	1.3	N
5/09/2025	TBY-WTP	7.1	1.3	N
6/09/2025	TBY-WTP	7.1	1.2	N
7/09/2025	TBY-WTP	7.1	1.2	N
8/09/2025	TBY-WTP	7.1	1.2	N
9/09/2025	TBY-WTP	7.1	1.2	N
10/09/2025	TBY-WTP	7.1	1.2	N
11/09/2025	TBY-WTP	7.1	1.3	N
12/09/2025	TBY-WTP	7.2	1.3	N
13/09/2025	TBY-WTP	7.1	1.3	N
14/09/2025	TBY-WTP	7.1	1.3	N
15/09/2025	TBY-WTP	7.1	1.2	N
16/09/2025	TBY-WTP	7.1	1.2	N
17/09/2025	TBY-WTP	7.1	1.2	N
18/09/2025	TBY-WTP	7.1	1.2	N
19/09/2025	TBY-WTP	7.1	1.2	N
20/09/2025	TBY-WTP	7.1	1.2	N
21/09/2025	TBY-WTP	7.1	1.2	N
22/09/2025	TBY-WTP	7.1	1.3	N
23/09/2025	TBY-WTP	7.1	1.3	N
24/09/2025	TBY-WTP	7.1	1.2	N
25/09/2025	TBY-WTP	7.1	1.1	N
26/09/2025	TBY-WTP	7.1	1.1	N
27/09/2025	TBY-WTP	7.1	1.0	N
28/09/2025	TBY-WTP	7.1	1.1	N
29/09/2025	TBY-WTP	7.1	1.1	N
30/09/2025	TBY-WTP	7.1	1.1	N

Burwood North- WTP Discharge Summary- September 2025

No discharge during September 2025