

The Bays- WTP Discharge Summary - October 2025

Discharge Date	Site/WTP	pH units	NTU	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units	NTU	Y/N
		6.5-8.5	18	Not visible
1/10/2025	TBY-WTP	7.1	1.1	N
2/10/2025	TBY-WTP	7.1	1.1	N
3/10/2025	TBY-WTP	7.1	1.1	N
4/10/2025	TBY-WTP	7.1	1.2	N
5/10/2025	TBY-WTP	7.1	1.1	N
6/10/2025	TBY-WTP	7.1	1.1	N
7/10/2025	TBY-WTP	7.1	1.2	N
8/10/2025	TBY-WTP	7.1	1.1	N
9/10/2025	TBY-WTP	7.1	1.2	N
10/10/2025	TBY-WTP	7.1	1.2	N
11/10/2025	TBY-WTP	7.1	1.2	N
12/10/2025	TBY-WTP	7.1	1.2	N
13/10/2025	TBY-WTP	7.1	1.2	N
14/10/2025	TBY-WTP	7.1	1.2	N
15/10/2025	TBY-WTP	7.1	1.2	N
16/10/2025	TBY-WTP	7.1	1.2	N
17/10/2025	TBY-WTP	7.1	1.2	N
18/10/2025	TBY-WTP	7.1	1.2	N
19/10/2025	TBY-WTP	7.1	1.2	N
20/10/2025	TBY-WTP	7.1	1.2	N
21/10/2025	TBY-WTP	7.1	1.2	N
22/10/2025	TBY-WTP	7.1	1.2	N
23/10/2025	TBY-WTP	7.1	1.2	N
24/10/2025	TBY-WTP	7.1	1.2	N
25/10/2025	TBY-WTP	7.1	1.2	N
26/10/2025	TBY-WTP	7.1	1.2	N
27/10/2025	TBY-WTP	7.1	1.3	N
28/10/2025	TBY-WTP	7.1	1.3	N
29/10/2025	TBY-WTP	7.2	1.3	N
30/10/2025	TBY-WTP	7.1	1.3	N
31/10/2025	TBY-WTP	7.1	1.3	N

Burwood North- WTP Discharge Summary- October 2025

No discharge during October 2025