

The Bays- WTP Discharge Summary - November 2025

Discharge Date	Site/WTP	pH units	NTU	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units	NTU	Y/N
		6.5-8.5	18	Not visible
1/11/2025	TBY-WTP	7.1	1.3	N
2/11/2025	TBY-WTP	7.1	1.3	N
3/11/2025	TBY-WTP	7.1	1.2	N
4/11/2025	TBY-WTP	7.1	1.2	N
5/11/2025	TBY-WTP	7.1	1.3	N
6/11/2025	TBY-WTP	7.1	1.2	N
7/11/2025	TBY-WTP	7.1	1.2	N
8/11/2025	TBY-WTP	7.1	1.2	N
9/11/2025	TBY-WTP	7.1	1.3	N
10/11/2025	TBY-WTP	7.1	1.2	N
11/11/2025	TBY-WTP	7.1	1.2	N
12/11/2025	TBY-WTP	7.1	1.3	N
13/11/2025	TBY-WTP	7.1	1.3	N
14/11/2025	TBY-WTP	7.1	1.2	N
15/11/2025	TBY-WTP	7.1	1.2	N
16/11/2025	TBY-WTP	7.1	1.2	N
17/11/2025	TBY-WTP	7.1	1.2	N
18/11/2025	TBY-WTP	7.1	1.2	N
19/11/2025	TBY-WTP	7.1	1.2	N
20/11/2025	TBY-WTP	7.1	1.2	N
21/11/2025	TBY-WTP	7.1	1.3	N
22/11/2025	TBY-WTP	7.1	1.3	N
23/11/2025	TBY-WTP	7.1	1.2	N
24/11/2025	TBY-WTP	7.1	1.2	N
25/11/2025	TBY-WTP	7.1	1.2	N
26/11/2025	TBY-WTP	7.1	1.2	N
27/11/2025	TBY-WTP	7.1	1.2	N
28/11/2025	TBY-WTP	7.1	1.2	N
29/11/2025	TBY-WTP	7.1	1.2	N
30/11/2025	TBY-WTP	7.1	1.2	N

Burwood North- WTP Discharge Summary- November 2025

No discharge during November 2025