

The Bays- WTP Discharge Summary - December 2025

Discharge Date	Site/WTP	pH units	NTU	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units	NTU	Y/N
		6.5-8.5	18	Not visible
1/12/2025	TBY-WTP	7.1	1.2	N
2/12/2025	TBY-WTP	7.1	1.3	N
3/12/2025	TBY-WTP	7.1	1.2	N
4/12/2025	TBY-WTP	7.1	1.2	N
5/12/2025	TBY-WTP	7.1	1.2	N
6/12/2025	TBY-WTP	7.1	1.2	N
7/12/2025	TBY-WTP	7.1	1.2	N
8/12/2025	TBY-WTP	7.1	1.2	N
9/12/2025	TBY-WTP	7.1	1.2	N
10/12/2025	TBY-WTP	7.1	1.2	N
11/12/2025	TBY-WTP	7.1	1.2	N
12/12/2025	TBY-WTP	7.1	1.2	N
13/12/2025	TBY-WTP	7.1	1.3	N
14/12/2025	TBY-WTP	7.1	1.3	N
15/12/2025	TBY-WTP	7.1	1.4	N
16/12/2025	TBY-WTP	7.1	1.4	N
17/12/2025	TBY-WTP	7.1	1.2	N
18/12/2025	TBY-WTP	7.1	1.1	N
19/12/2025	TBY-WTP	7.1	1.1	N
20/12/2025	TBY-WTP	7.1	1.1	N
21/12/2025	TBY-WTP	7.1	1.1	N
22/12/2025	TBY-WTP	7.1	1.3	N
23/12/2025	TBY-WTP	7.1	1.3	N
24/12/2025	TBY-WTP	7.1	1.3	N
25/12/2025	TBY-WTP	7.1	1.4	N
26/12/2025	TBY-WTP	7.1	1.5	N
27/12/2025	TBY-WTP	7.1	1.7	N
28/12/2025	TBY-WTP	7.1	1.7	N
29/12/2025	TBY-WTP	7.1	1.7	N
30/12/2025	TBY-WTP	7.1	1.7	N
31/12/2025	TBY-WTP	7.1	1.7	N

Burwood North- WTP Discharge Summary- December 2025

No discharge during December 2025